

## Addendum No. 2

**DATE:** April 5, 2010  
**TO:** Prospective Bidders  
**FROM:** Rjahja Canlas, Park Development Analyst  
**RE:** Bud Nichols Park Project

---

Notice is hereby given that the following clarifications, corrections, additions, and/or deletions shall apply to the Contract Documents for the above referenced project. This addendum shall be made a part thereof, and subject to all requirements thereof, as if originally drawn or specified.

**Receipt of Addendum No. 2 must be acknowledged in writing on page PROP-1 of the Proposal.**

**Project Manual:**

**Item 1.1** *Add Section 02760: Miscellaneous Site Amenities, Paragraph 2.01 N.:*

- L. Park Namesake Plaque shall be a 24" by 18" digital high pressure laminate graphic panel fabricated or accepted equal. Plaque shall be mounted on a SlimLine single pedestal sign system or accepted equal. Manufacturer for the plaque and sign system (model # 2418 SL-SLP-AL) is KVO Industries (Chris Howell, 707.573.6868). Installation location shall be verified in the field with the Project Manager.

**Item 1.2** *Amend Section 02900: Landscaping, Paragraph 2.02 B. to read:*

- B. Turf seed mix shall be Princess 77 Bermuda.

**Item 1.3** *Replace Section 16000: Site Electrical, Paragraph 2.10. with:*

2.10 Fixtures and Poles

- A. Pathway/Security lights shall be:

Beacon Products, Traditional Luminaire,  
Model # TRA30/AC/LED48-120/IND5/PEC/SWT/BB  
Contact: Bill Click, CJS Lighting, 916.774.6888

or, Hadco, Fentress,  
Model # RL54 B B N N 1 A R 4K L55 N  
Contact: Patrick Robitaille, ALR, 916.383.4545 x 223

or accepted equal, with:

1. acrylic lens
2. twist lock photocell,
3. cast aluminum
4. type V, symmetric photometric distribution,
5. Rated 120 volts, LED

B. Poles shall be:

Whatley, Composite Pole  
Model # RT34-14 BLK DE TXT 30 -30  
Contact: Melanie Gador, Lighting Systems, 916.772.5800

or accepted equal:

1. fiberglass,
2. 14' mounting height,
3. 18' total shaft length,
4. direct burial

**Q&A:  
Item 1.4**

*Responses to questions submitted:*

Question: Is there a pre-bid meeting scheduled and is the meeting mandatory to attend in order to bid?

Answer: There are no pre-bid meetings scheduled for this project

Question: What kind of documentation do you need to full fill the below statement from the proposal form?

“If a bidder submits bids for both Bud Nichols Park (W-52) and Fred Festersen Park (W-55), the bidder shall submit documentation that demonstrates the bidder has the resources to complete both projects simultaneously.”

Answer: The City does not require a specific type of documentation to fulfill this requirement. Bidders can submit any documentation that shows they have the resources to complete both projects simultaneously.

**End of Addendum No. 2**